

NCC 2019 and NCC 2019 Amendment 1 are corrected by this corrigendum as follows:

## Schedule 4 Referenced documents

**Delete Note (2) to Table 1 and insert Note (2) as follows:**

- (2) For AS 1530 Parts 1 to 4:
- (a) Until 1 May 2023, subject to the note to AS 4072.1, reports relating to tests carried out under earlier editions of AS 1530 Parts 1 to 4 remain valid.
  - (b) Reports relating to tests carried out after the date of an amendment to a Standard must relate to the amended Standard.

**Delete Note (4) to Table 1 and insert Note (4) as follows:**

- (4) For AS 1670.1, AS 1670.3 and AS 1670.4, notwithstanding A4.0(5), until the adoption of NCC 2025 the editions of the documents listed in Table 1.8 of AS 1670.1, AS 1670.3 and AS 1670.4 may be used to meet the requirements of AS 1670.1, AS 1670.3 and AS 1670.4 as applicable.

**Delete Note (9) to Table 1 and insert Note (9) as follows:**

- (9) For AS 4072.1, until 1 May 2023, systems tested to AS 1530.4 prior to 1 January 1995 need not be retested to comply with the provisions of AS 4072.1.

## List of amendments (NCC 2019 only)

### Schedule 4—Documents adopted by reference

**Delete row for AS 1530 and insert row for AS 1530 as follows:**

Reference	Changes and Commentary
AS 1530	The note to AS 1530 permitting use of reports relating to tests carried out under earlier editions of AS 1530 Parts 1, 2 and 4 has been amended to include an expiry date of 1 May 2023.

**Delete row for AS 4072.1 and insert row for AS 4072.1 as follows:**

Reference	Changes and Commentary
AS 4072.1	The note to AS 4072.1 permitting use of reports relating to tests carried out under AS 1530.4 prior to 1 January 1995 has been amended to include an expiry date of 1 May 2023.

Issued by the Australian Building Codes Board  
 Version: 2.0 [Supersedes version 1.0]  
 Release date: 31/08/2022